

Barry Hannon

From: Carol Heaton
Sent: 11 May 2021 14:59
To: eConsultation Mailbox
Cc: Aisling Divin; Ron Wylie; Julie Thomson
Subject: 21/00687/FUL - Extension to House - 11 Kent Road, Uddingston

Categories: Barry

FAO Aisling Divin

Pollution Control has received a consultation request with regards to the following application:

Ref: 21/00687/FUL

Proposed Works: Two Storey Side Extension to House

Site Address: 11 Kent Road, Uddingston

Comment as follows:

The site is located on potentially contaminated land. Where appropriate, suitable steps require to be taken to ensure that any measures previously provided in connection with the building, in relation to contaminated land remediation, are not damaged or compromised during construction.

If gas preclusion measures were incorporated into the original building then the same measures should also be incorporated into the proposed works.

Should the presence of any previously unsuspected contamination become evident during the development of the site it shall be brought to the attention of this Department within one week or earlier. At this stage, a more detailed site investigation to determine the extent and nature of the contaminant(s), and a site specific risk assessment of any associated hazards may be required.

Carol Heaton
Environmental Health Officer
North Lanarkshire Council
Regulatory Services & Waste Solutions
Protective Services
Environmental Health – Pollution Control & Public Health
Civic Centre, Windmillhill Street, Motherwell, ML1 1AB
07951 412328

North Lanarkshire Council is registered under the Data Protection Act 2018 and at all times will comply with the terms of the Act when processing your personal data.

For further information on how we process your personal data please follow this link to the North Lanarkshire Council website: <https://www.northlanarkshire.gov.uk/index.aspx?articleid=12657>